

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Elkins Hall
906 East 1st St.
Thibodaux, LA 70301

Location ID:
329003-1

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/1/2023

Inspection Start Time: 7:00:00 AM

Inspection End Time: 8:00:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0597

Device Type: Hydraulic Elevator

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 9/22/1984

Device Manufacturer: Esco

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 2000


Speed: 100

Inspector Notes:

Testing Results: Relief (psi): 460, Working (psi): 200,

Violation Information:

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0597	Device Type: Hydraulic Elevator	Date: 3/1/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Mike Robison	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	2 INSIDE OF CAR	OK	NG	N/A
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices	X			3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks			X
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways			X
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)	X			3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch			X
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices	X		
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members	X		
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000	X		
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00	X		
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04	X		
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07	X		
				6.8 A17.1-2010/B44-10	X		
				6.9 A17.1-2013/B44-13	X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Ellender Hall
Highway 1
Thibodaux, LA 70301

Location ID:
329003-20

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/3/2023

Inspection Start Time: 10:00:00 AM

Inspection End Time: 11:30:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: T0276

Device Type: Traction Elevator

of Landings:

Due Month: March

Device Use:

Device Designation: 4842

Code Edition: 2007 / CSA B44 - A17.1

Installation Date: 9/23/2011

Device Manufacturer: EC

Cat 5 Required?

Capacity: 2500

Speed: 350

Inspector Notes:

Testing Results:

Violation Information:

New Violations

<u>Violation</u>	<u>Inspector Comments</u>
2.18 Traction Drive Machines	Vibration coming from the drive machine make corrections

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
2.18 Traction Drive Machines	Install guard on machine	No

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address: Ellender Hall, Highway 1, Thibodaux, LA 70301

ID No: T0276

Device Type: Traction Elevator

Date: 3/3/2023


Inspection Type: Category 1 Test

Firm #: 33

Code Edition: 2007 / CSA B44 - A17.1

Location Contact Name: Mike Robison

Inspected By: Smith, Willie ||

Signature: 

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR									
1.1 Door reopening device	X								
1.2 Stop Switches	X								
1.3 Operating control devices	X								
1.4 Sills and car floor	X								
1.5 Car lighting and receptacles	X								
1.6 Car emergency signal	X								
1.7 Car door or gate	X								
1.8 Door closing force	X								
1.9 Power closing of doors or gates	X								
1.10 Power opening of doors or gates	X								
1.11 Car vision panels and glass car doors				X					
1.12 Car enclosure	X								
1.13 Emergency exit	X								
1.14 Ventilation	X								
1.15 Signs and operating device symbols	X								
1.16 Rated load, platform area, and data plate	X								
1.17 Standby power operation	X								
1.18 Restricted opening of car or hoistway doors	X								
1.19 Car ride	X								
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)				X					
2 MACHINE ROOM									
2.1 Access to machinery space	X								
2.2 Headroom	X								
2.3 Lighting and receptacles	X								
2.4 Machinery space	X								
2.5 Housekeeping	X								
2.6 Ventilation	X								
2.7 Fire extinguisher	X								
2.8 Pipes, wiring, and ducts	X								
2.9 Guarding of exposed auxiliary equipment	X								
2.10 Numbering of elevators, machines, controllers & disconnect switches	X								
2.11 Disconnecting means and control	X								
2.12 Controller wiring, fuses, grounding, etc.	X								
2.13 Governor, overspeed switch, and seal	X								
2.14 Code data plate	X								
2.15 Static control	X								
2.16 Overhead beam and fastenings	X								
2.17 Drive machine brake	X								
2.18 Traction-drive machines			X						
2.19 Gears, bearings, and flexible couplings	X								
2.20 Winding drum machine & slack rope device, stop-motion switch, & rope fastening	X								
2.21 Belt- or chain-drive machine	X								
2.22 Motor generator	X								
2.23 Absorption of regenerated power	X								
2.24 AC drives from a DC source	X								
2.25 Traction sheaves	X								
2.26 Secondary and deflector sheaves	X								
2.27 Rope fastenings	X								
2.28 Terminal stopping devices	X								
2.29 Car and counterweight safeties	X								
2.40 Maintenance records	X								
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)				X					
3 TOP OF CAR									
3.1 Top-of-car stop switch	X								
3.2 Car top light and outlet	X								
3.3 Top-of-car operating device	X								
3.4 Top-of-car clearance, refuge space, and standard railing	X								
3.5 Normal terminal stopping devices	X								
3.6 Final and emergency terminal stopping devices	X								
3.7 Car leveling and anticreep devices	X								
3.8 Top emergency exit	X								
3.9 Floor and emergency identification numbering	X								
3.10 Hoistway construction	X								
3.11 Hoistway smoke control	X								
3.12 Pipes, wiring, and ducts	X								
3.13 Windows, projections, recesses, and setbacks					X				
3.14 Hoistway clearances	X								
3.15 Multiple hoistways						X			
3.16 Traveling cables and junction boxes	X								
3.17 Door and gate equipment	X								
3.18 Car frame and stiles	X								
3.19 Guide rails, fastenings, and equipment	X								
3.20 Governor rope	X								
3.21 Governor releasing carrier	X								
3.22 Wire rope fastening and hitch plate	X								
3.23 Suspension compensation and governor systems	X								
3.27 Crosshead data plate and rope data tags	X								
3.28 Counterweight and counterweight buffer	X								
3.29 Counterweight safeties								X	
3.30 Speed Test						X			
3.33 Compensating ropes and chains						X			
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)									X
4 OUTSIDE HOISTWAY									
4.1 Car platform guard						X			
4.2 Hoistway doors						X			
4.3 Vision panels								X	
4.4 Hoistway door-locking devices						X			
4.5 Access to hoistway						X			
4.6 Power closing of hoistway doors						X			
4.7 Sequence operation						X			
4.8 Hoistway enclosure						X			
4.9 Elevator parking devices									X
4.10 Emergency doors in blind hoistways									X
4.12 Standby power selection switch									X
5 PIT									
5.1 Pit access, lighting, stop switch & condition						X			
5.2 Bottom clearance, runby & minimum refuge space						X			
5.3 Final and emergency terminal stopping devices						X			
5.4 Normal terminal stopping devices						X			
5.5 Traveling cables						X			
5.6 Governor-rope tension devices						X			
5.7 Car frame and platform						X			
5.8 Car and counterweight safeties and guiding members						X			
5.9 Buffers and emergency terminal speed-limiting devices						X			
5.10 Compensating chains, ropes & sheaves						X			
5.12 Car buffers						X			
5.13 Guiding members [rails, rollers, slides]						X			
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)									X
6 FIREFIGHTERS' SERVICE (FEO)									
6.1 A17.1b-1973 through A17.1b-1980						X			
6.2 17.1-1981 through A17.1b-1983						X			
6.3 A17.1-1984 through A17.1a-1988 and A17.3						X			
6.4 A17.1b-1989 through A17.1d-2000						X			
6.5 A 17.1-2000/644-00						X			
6.6 A 17.1-2004/644-04						X			
6.7 A17.1-2007/B44-07						X			
6.8 A17.1-2010/B44-10						X			
6.9 A17.1-2013/B44-13						X			

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Ray E. Didier Field Pressbox/
Concession Stand
331 Colonel Dr
Thibodaux, LA 70301

Location ID:
329003-119

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/2/2023

Inspector: Smith, Willie ||

Re-Inspection Required:

Device ID: H0593

Due Month: March

Code Edition:

Overspeed Valve?

Capacity: 2500

Inspector Notes:

Testing Results:

Inspection Start Time:

Inspection Type:

Generator Test Performed:

Device Type: Hydraulic Elevator

Device Use:

Installation Date:

Plunger Gripper?

Speed: 100

Inspection End Time:

Inspection Result:

Re-Inspection Maint Co Required:

of Landings:

Device Designation:

Device Manufacturer: Tke

Cat 5 Required?

Violation Information:

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0593

Device Type: Hydraulic Elevator

Date: 3/2/2023


Inspection Type:

Firm #: 33

Code Edition:

Location Contact Name: Mike Robison

Inspected By: Smith, Willie ||

Signature: 

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1	INSIDE OF CAR	OK	NG	N/A	OK	NG	N/A
1.1	Door reopening device	X					
1.2	Stop Switches	X					
1.3	Operating control devices	X					
1.4	Sills and car floor	X					
1.5	Car lighting and receptacles	X					
1.6	Car emergency signal	X					
1.7	Car door or gate	X					
1.8	Door closing force	X					
1.9	Power closing of doors or gates	X					
1.10	Power opening of doors or gates	X					
1.11	Car vision panels and glass car doors	X					
1.12	Car enclosure	X					
1.13	Emergency exit	X					
1.14	Ventilation	X					
1.15	Signs and operating device symbols	X					
1.16	Rated load, platform area, and data plate	X					
1.17	Standby power operation	X					
1.18	Restricted opening of car or hoistway doors	X					
1.19	Car ride	X					
1.20	Earthquake inspection and tests (seismic risk zone 2 or greater)	X					
2	MACHINE ROOM	OK	NG	N/A	OK	NG	N/A
2.1	Access to machinery space	X					
2.2	Headroom	X					
2.3	Lighting and receptacles	X					
2.4	Machinery space	X					
2.5	Housekeeping	X					
2.6	Ventilation	X					
2.7	Fire extinguisher	X					
2.8	Pipes, wiring, and ducts	X					
2.9	Guarding of exposed auxiliary equipment	X					
2.10	Numbering of elevators, machines, controllers & disconnect switches	X					
2.11	Disconnecting means and control	X					
2.12	Controller wiring, fuses, grounding, etc.	X					
2.13	Governor, overspeed switch, and seal	X					
2.14	Code data plate	X					
2.30	Hydraulic power unit	X					
2.31	Relief valves	X					
2.32	Control valve	X					
2.33	Tanks	X					
2.36	Hydraulic cylinders	X					
2.37	Pressure switch	X					
2.38	Roped water hydraulic elevators	X					
2.39	Low oil protection	X					
2.40	Maintenance records	X					
2.41	Hydraulic control	X					
2.42	Earthquake inspection and tests (seismic risk zone 2 or greater)	X					
2.44	Auxillary power lowering operation	X					
2.45	Inspection operation with open door circuits and inspection hierarchy	X					
3	TOP OF CAR	OK	NG	N/A	OK	NG	N/A
3.1	Top-of-car stop switch	X					
3.2	Car top light and outlet	X					
3.3	Top-of-car operating device	X					
3.4	Top-of-car clearance, refuge space, and standard railing	X					
3.5	Normal terminal stopping devices	X					
3.6	Final and emergency terminal stopping devices	X					
3.7	Top-of-car operating device	X					
3.8	Top-of-car clearance, refuge space, and standard railing	X					
4	OUTSIDE HOISTWAY	OK	NG	N/A	OK	NG	N/A
4.1	Car platform guard	X					
4.2	Hoistway doors	X					
4.3	Vision panels	X					
4.4	Hoistway door-locking devices	X					
4.5	Access to hoistway	X					
4.6	Power closing of hoistway doors	X					
4.7	Sequence operation	X					
4.8	Hoistway enclosure	X					
4.9	Elevator parking devices	X					
4.10	Emergency doors in blind hoistways	X					
4.12	Standby power selection switch	X					
5	PIT	OK	NG	N/A	OK	NG	N/A
5.1	Pit access, lighting, stop switch & condition	X					
5.2	Bottom clearance, runby & minimum refuge space	X					
5.4	Normal terminal stopping devices	X					
5.5	Traveling cables	X					
5.6	Governor-rope tension devices	X					
5.7	Car frame and platform	X					
5.8	Car and counterweight safeties and guiding members	X					
5.11	Buffers and emergency terminal speed-limiting devices	X					
5.12	Car buffers	X					
5.13	Guiding members [rails, rollers, slides]	X					
5.14	Guiding members [rails, rollers, slides]	X					
5.15	Overspeed valve	X					
5.16	Earthquake inspection and tests (seismic risk zone 2 or greater)	X					
5.17	Plunger gripper	X					
6	FIREFIGHTERS' SERVICE (FEO)	OK	NG	N/A	OK	NG	N/A
6.1	A17.1-1984 through A17.1a-1988 and A17.3	X					
6.2	A17.1b-1989 through A17.1d-2000	X					
6.3	A17.1-1984 through A17.1a-1988 and A17.3	X					
6.4	A17.1b-1989 through A17.1d-2000	X					
6.5	A 17.1-2000/644-00	X					
6.6	A 17.1-2004/644-04	X					
6.7	A17.1-2007/B44-07	X					
6.8	A17.1-2010/B44-10	X					
6.9	A17.1-2013/B44-13	X					

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address: College Of Education And Behavioral Sciences Building 105 Ellendale Dr Thibodaux, LA 70310	Location ID: 329003-12	Location Contact Information: Name: Mike Robison Title: Phone: +19854484773 Email: mike.robison@nicholls.edu
---	----------------------------------	--


Inspection Information:

Inspection Date: 3/1/2023	Inspection Start Time: 1:00:00 PM	Inspection End Time: 2:00:00 PM
Inspector: Smith, Willie	Inspection Type: Category 1 Test	Inspection Result: Passed - Violations
Re-Inspection Required: No	Generator Test Performed: No	Re-Inspection Maint Co Required: No
Device ID: H0602	Device Type: Hydraulic Elevator	# of Landings: 2
Due Month: March	Device Use:	Device Designation: Polk Hall
Code Edition:	Installation Date: 9/22/1963	Device Manufacturer: Dover
Overspeed Valve?	Plunger Gripper?	Cat 5 Required?
Capacity: 2500	Speed: 100	
Inspector Notes:		
Testing Results: Relief (psi): 540, Working (psi): 230,		

Violation Information:

Previous Violations	Inspector Comments	Corrected?
<u>Previous Violation</u> 1.18 Restricted opening of car or hoistway doors	<u>Inspector Comments</u> Install door restrictor	<u>Corrected?</u> No
3.14 Hoistway clearances	Install cartoon handrail	No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0602	Device Type: Hydraulic Elevator	Date: 3/1/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Mike Robison	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	OK	NG	N/A
1.1 Door reopening device	X			X		
1.2 Stop Switches	X			X		
1.3 Operating control devices	X			X		
1.4 Sills and car floor	X			X		
1.5 Car lighting and receptacles	X					X
1.6 Car emergency signal	X				X	
1.7 Car door or gate	X					X
1.8 Door closing force	X			X		
1.9 Power closing of doors or gates	X			X		
1.10 Power opening of doors or gates	X			X		
1.11 Car vision panels and glass car doors	X			X		
1.12 Car enclosure	X					X
1.13 Emergency exit	X					X
1.14 Ventilation	X					X
1.15 Signs and operating device symbols	X					X
1.16 Rated load, platform area, and data plate	X			X		
1.17 Standby power operation	X					X
1.18 Restricted opening of car or hoistway doors		X				X
1.19 Car ride	X			X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X			X
2 MACHINE ROOM						
2.1 Access to machinery space	X					
2.2 Headroom	X					
2.3 Lighting and receptacles	X					
2.4 Machinery space	X					
2.5 Housekeeping	X					
2.6 Ventilation	X					
2.7 Fire extinguisher	X					
2.8 Pipes, wiring, and ducts	X					
2.9 Guarding of exposed auxiliary equipment	X					
2.10 Numbering of elevators, machines, controllers & disconnect switches	X					
2.11 Disconnecting means and control	X					
2.12 Controller wiring, fuses, grounding, etc.	X					
2.13 Governor, overspeed switch, and seal			X			
2.14 Code data plate	X					
2.30 Hydraulic power unit	X					
2.31 Relief valves	X					
2.32 Control valve	X					
2.33 Tanks	X					
2.36 Hydraulic cylinders	X					
2.37 Pressure switch	X					
2.38 Roped water hydraulic elevators			X			
2.39 Low oil protection	X					
2.40 Maintenance records	X					
2.41 Hydraulic control	X					
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X			
2.44 Auxillary power lowering operation	X					
2.45 Inspection operation with open door circuits and inspection hierarchy	X					
3 TOP OF CAR						
3.1 Top-of-car stop switch	X					
3.2 Car top light and outlet	X					
3.3 Top-of-car operating device	X					
3.4 Top-of-car clearance, refuge space, and standard railing	X					
3.5 Normal terminal stopping devices	X					
3.6 Final and emergency terminal stopping devices	X					
3.7 Top-of-car operating device	X					
3.8 Top-of-car clearance, refuge space, and standard railing	X					
3.9 Floor and emergency identification numbering	X					
3.10 Hoistway Construction	X					
3.11 Hoistway smoke control	X					
3.12 Pipes, wiring, and ducts	X					
3.13 Windows, projections, recesses, and setbacks						X
3.14 Hoistway clearances			X			
3.15 Multiple hoistways						X
3.16 Traveling cables and junction boxes	X					
3.17 Door and gate equipment	X					
3.18 Car frame and stiles	X					
3.19 Guide rails, fastenings, and equipment	X					
3.20 Governor rope						X
3.21 Governor releasing carrier						X
3.22 Wire rope fastening and hitch plate						X
3.23 Suspension compensation and governor systems						X
3.27 Crosshead data plate and rope data tags	X					
3.28 Counterweight and counterweight buffer						X
3.29 Counterweight safeties						X
3.30 Speed Test	X					
3.31 Slack rope test - roped hydraulic elevators						X
3.32 Speed Test						X
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)						X
4 OUTSIDE HOISTWAY						
4.1 Car platform guard	X					
4.2 Hoistway doors	X					
4.3 Vision panels	X					
4.4 Hoistway door-locking devices	X					
4.5 Access to hoistway	X					
4.6 Power closing of hoistway doors	X					
4.7 Sequence operation	X					
4.8 Hoistway enclosure	X					
4.9 Elevator parking devices						X
4.10 Emergency doors in blind hoistways						X
4.12 Standby power selection switch						X
5 PIT						
5.1 Pit access, lighting, stop switch & condition	X					
5.2 Bottom clearance, runby & minimum refuge space	X					
5.4 Normal terminal stopping devices	X					
5.5 Traveling cables	X					
5.6 Governor-rope tension devices						X
5.7 Car frame and platform	X					
5.8 Car and counterweight safeties and guiding members						X
5.11 Buffers and emergency terminal speed-limiting devices	X					
5.12 Car buffers	X					
5.13 Guiding members [rails, rollers, slides]	X					
5.14 Guiding members [rails, rollers, slides]	X					
5.15 Overspeed valve						X
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)						X
5.17 Plunger gripper						X
6 FIREFIGHTERS' SERVICE (FEO)						
6.1 A17.1-1984 through A17.1a-1988 and A17.3	X					
6.2 A17.1b-1989 through A17.1d-2000	X					
6.3 A17.1-1984 through A17.1a-1988 and A17.3	X					
6.4 A17.1b-1989 through A17.1d-2000	X					
6.5 A 17.1-2000/644-00	X					
6.6 A 17.1-2004/644-04	X					
6.7 A17.1-2007/B44-07	X					
6.8 A17.1-2010/B44-10	X					
6.9 A17.1-2013/B44-13	X					

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Talbot Hall
106 Ellendale Drive (Entrance L)
Thibodaux, LA 70310

Location ID:
329003-022

Location Contact Information:

Name: Chad Legendre
Title:
Phone: +19854484785
Email: chad.legendre@nicholls.edu

Inspection Information:

Inspection Date: 3/2/2023

Inspection Start Time: 7:00:00 AM

Inspection End Time: 8:00:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0604

Device Type: Hydraulic Elevator

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 9/22/1964

Device Manufacturer: Otis

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 3500

Speed: 150

Inspector Notes:


Testing Results:

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
2.30 Hydraulic power unit	Install a shut off valve in the MR	No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0604	Device Type: Hydraulic Elevator	Date: 3/2/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Chad Legendre	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	OK NG N/A			
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices	X			3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways			X
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors			X	3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate	X		
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation			X	3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators	X		
2 MACHINE ROOM				3.32 Speed Test	X		
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)	X		
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices			X
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch			X
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit			X	5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy			X	5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
				5.17 Plunger gripper			X
3 TOP OF CAR				6 FIREFIGHTERS' SERVICE (FEO)			
3.1 Top-of-car stop switch	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3			X
3.2 Car top light and outlet	X			6.2 A17.1b-1989 through A17.1d-2000	X		
3.3 Top-of-car operating device	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.5 Normal terminal stopping devices	X			6.5 A 17.1-2000/644-00	X		
3.6 Final and emergency terminal stopping devices	X			6.6 A 17.1-2004/644-04	X		
3.7 Top-of-car operating device	X			6.7 A17.1-2007/B44-07	X		
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.8 A17.1-2010/B44-10	X		
				6.9 A17.1-2013/B44-13	X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Powell Hall
103 Glenwood Dr.
Thibodaux, LA 70301

Location ID:
329003-23

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/1/2023

Inspection Start Time: 8:00:00 AM

Inspection End Time: 9:00:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0121

Device Type: Hydraulic Elevator

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 9/22/1984

Device Manufacturer: Dover

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 1200

Speed: 100

Inspector Notes:

Testing Results: Relief (psi): 430, Working (psi): 240,

Violation Information:

Previous Violations

Previous Violation

1.5 Car lighting and receptacles


Inspector Comments

Repair emergency lighting it disables the car operation

Corrected?

No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0121	Device Type: Hydraulic Elevator	Date: 3/1/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Mike Robison	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	OK	NG	N/A
1.1 Door reopening device	X			X		
1.2 Stop Switches	X			X		
1.3 Operating control devices	X			X		
1.4 Sills and car floor	X			X		
1.5 Car lighting and receptacles		X				X
1.6 Car emergency signal	X			X		
1.7 Car door or gate	X			X		
1.8 Door closing force	X			X		
1.9 Power closing of doors or gates	X			X		
1.10 Power opening of doors or gates	X			X		
1.11 Car vision panels and glass car doors	X			X		
1.12 Car enclosure	X			X		
1.13 Emergency exit	X			X		
1.14 Ventilation	X			X		
1.15 Signs and operating device symbols	X			X		
1.16 Rated load, platform area, and data plate	X			X		
1.17 Standby power operation	X			X		
1.18 Restricted opening of car or hoistway doors	X			X		
1.19 Car ride	X			X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X			X
2 MACHINE ROOM						
2.1 Access to machinery space	X			X		
2.2 Headroom	X			X		
2.3 Lighting and receptacles	X			X		
2.4 Machinery space	X			X		
2.5 Housekeeping	X			X		
2.6 Ventilation	X			X		
2.7 Fire extinguisher	X			X		
2.8 Pipes, wiring, and ducts	X			X		
2.9 Guarding of exposed auxiliary equipment	X			X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			X		
2.11 Disconnecting means and control	X			X		
2.12 Controller wiring, fuses, grounding, etc.	X			X		
2.13 Governor, overspeed switch, and seal			X			X
2.14 Code data plate	X			X		
2.30 Hydraulic power unit	X			X		
2.31 Relief valves	X			X		
2.32 Control valve	X			X		
2.33 Tanks	X			X		
2.36 Hydraulic cylinders	X			X		
2.37 Pressure switch	X			X		
2.38 Roped water hydraulic elevators			X			X
2.39 Low oil protection	X			X		
2.40 Maintenance records	X			X		
2.41 Hydraulic control	X			X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)	X			X		
2.44 Auxillary power lowering operation	X			X		
2.45 Inspection operation with open door circuits and inspection hierarchy	X			X		
3 TOP OF CAR						
3.1 Top-of-car stop switch	X			X		
3.2 Car top light and outlet	X			X		
3.3 Top-of-car operating device	X			X		
3.4 Top-of-car clearance, refuge space, and standard railing	X			X		
3.5 Normal terminal stopping devices	X			X		
3.6 Final and emergency terminal stopping devices	X			X		
3.7 Top-of-car operating device	X			X		
3.8 Top-of-car clearance, refuge space, and standard railing	X			X		
3.9 Floor and emergency identification numbering	X			X		
3.10 Hoistway Construction	X			X		
3.11 Hoistway smoke control	X			X		
3.12 Pipes, wiring, and ducts	X			X		
3.13 Windows, projections, recesses, and setbacks			X			X
3.14 Hoistway clearances	X			X		
3.15 Multiple hoistways	X			X		
3.16 Traveling cables and junction boxes	X			X		
3.17 Door and gate equipment	X			X		
3.18 Car frame and stiles	X			X		
3.19 Guide rails, fastenings, and equipment	X			X		
3.20 Governor rope			X			X
3.21 Governor releasing carrier			X			X
3.22 Wire rope fastening and hitch plate			X			X
3.23 Suspension compensation and governor systems			X			X
3.27 Crosshead data plate and rope data tags	X			X		
3.28 Counterweight and counterweight buffer			X			X
3.29 Counterweight safeties			X			X
3.30 Speed Test	X			X		
3.31 Slack rope test - roped hydraulic elevators			X			X
3.32 Speed Test			X			X
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X			X
4 OUTSIDE HOISTWAY						
4.1 Car platform guard	X			X		
4.2 Hoistway doors	X			X		
4.3 Vision panels	X			X		
4.4 Hoistway door-locking devices	X			X		
4.5 Access to hoistway	X			X		
4.6 Power closing of hoistway doors	X			X		
4.7 Sequence operation	X			X		
4.8 Hoistway enclosure	X			X		
4.9 Elevator parking devices			X			X
4.10 Emergency doors in blind hoistways			X			X
4.12 Standby power selection switch			X			X
5 PIT						
5.1 Pit access, lighting, stop switch & condition	X			X		
5.2 Bottom clearance, runby & minimum refuge space	X			X		
5.4 Normal terminal stopping devices	X			X		
5.5 Traveling cables	X			X		
5.6 Governor-rope tension devices			X			X
5.7 Car frame and platform	X			X		
5.8 Car and counterweight safeties and guiding members			X			X
5.11 Buffers and emergency terminal speed-limiting devices	X			X		
5.12 Car buffers	X			X		
5.13 Guiding members [rails, rollers, slides]	X			X		
5.14 Guiding members [rails, rollers, slides]	X			X		
5.15 Overspeed valve			X			X
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X			X
5.17 Plunger gripper			X			X
6 FIREFIGHTERS' SERVICE (FEO)						
6.1 A17.1-1984 through A17.1a-1988 and A17.3	X			X		
6.2 A17.1b-1989 through A17.1d-2000	X			X		
6.3 A17.1-1984 through A17.1a-1988 and A17.3	X			X		
6.4 A17.1b-1989 through A17.1d-2000	X			X		
6.5 A 17.1-2000/644-00	X			X		
6.6 A 17.1-2004/644-04	X			X		
6.7 A17.1-2007/B44-07	X			X		
6.8 A17.1-2010/B44-10	X			X		
6.9 A17.1-2013/B44-13	X			X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Talbot Hall
106 Ellendale Drive (Entrance L)
Thibodaux, LA 70310

Location ID:
329003-022

Location Contact Information:

Name: Chad Legendre
Title:
Phone: +19854484785
Email: chad.legendre@nicholls.edu

Inspection Information:

Inspection Date: 3/2/2023

Inspection Start Time: 10:00:00 AM

Inspection End Time: 10:30:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: L0034

Device Type: Wheelchair Lift

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 9/22/2009

Device Manufacturer: National wheel o vator

Cat 5 Required?

Capacity: 750

Speed: 10

Inspector Notes:

Testing Results:

Violation Information:

Checklist and Report for Inspection of Lifts ASME A18.1-2020 Requirement: 10.2.2

ID No: L0034

Device Type: Wheelchair Lift

Date: 3/2/2023


Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: Chad Legendre

Inspected By: Smith, Willie ||

Signature: 

Location Contact Signature:

Notes: OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

A	INSIDE PLATFORM INSPECTIONS	OK	NG	N/A	C	INSIDE RUNWAY INSPECTIONS	OK	NG	N/A
1	Stop switches	X			1	Platform, overhead, and deflector sheaves	X		
2	Operating control devices	X			2	Normal terminal stopping devices	X		
3	Floor and landing sill	X			3	Final terminal stopping devices	X		
4	Lighting	X			4	Broken rope, chain, or tape switch	X		
5	Emergency signal	X			5	Counterweight	X		
6	Door or gate	X			6	Head room	X		
7	Enclosure	X			7	Slack-rope devices	X		
8	Floor	X			8	Traveling sheave	X		
9	Signs and operating device symbols	X			9	Platform safeties and guiding members	X		
10	Rate load, platform floor area and data plate	X			10	Runway construction	X		
11	Ride	X			11	Pipes, wiring and ducts	X		
B MACHINE INSPECTIONS					D OUTSIDE RUNWAY INSPECTIONS				
1	Enclosure of machine space	X			12	Runway clearances	X		
2	Guarding of exposed auxiliary equipment	X			13	Traveling cables and junction boxes	X		
3	Overhead beam and fastenings	X			14	Door and gate equipment	X		
4	Drive-machine brake	X			15	Platform frame	X		
5	Traction drive machines	X			16	Guide rails fastening and equipment	X		
6	Gears and bearings	X			17	Governor rope	X		
7	Winding drum machine	X			18	Governor releasing carrier	X		
8	Belt- or chain-drive machine	X			19	Wire rope fastening and hitch plate	X		
9	Traction sheaves	X			20	Suspension rope	X		
10	Secondary and deflector sheaves	X			21	Compensation ropes and chains	X		
11	Rope fastenings	X			1	Runway doors	X		
12	Slack-rope devices	X			2	Runway door locking devices	X		
13	Governor, overspeed switch and seal	X			3	Runway enclosure	X		
14	Platform safeties	X							
15	Hydraulic power unit	X							
16	Control valves	X							
17	Hydraulic cylinders	X							

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address: College Of Education And Behavioral Sciences Building 105 Ellendale Dr Thibodaux, LA 70310	Location ID: 329003-12	Location Contact Information: Name: Mike Robison Title: Phone: +19854484773 Email: mike.robison@nicholls.edu
---	----------------------------------	--


Inspection Information:

Inspection Date: 3/1/2023	Inspection Start Time: 12:00:00 AM	Inspection End Time: 1:00:00 PM
Inspector: Smith, Willie	Inspection Type: Category 1 Test	Inspection Result: Passed - Violations
Re-Inspection Required: No	Generator Test Performed: No	Re-Inspection Maint Co Required: No
Device ID: H0601	Device Type: Hydraulic Elevator	# of Landings:
Due Month: March	Device Use:	Device Designation: Polk Hall
Code Edition:	Installation Date: 3/15/1962	Device Manufacturer: Esco
Overspeed Valve?	Plunger Gripper?	Cat 5 Required?
Capacity: 1200	Speed: 100	
Inspector Notes:		
Testing Results: Relief (psi): 430, Working (psi): 180,		

Violation Information:

Previous Violations	Inspector Comments	Corrected?
<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.18 Restricted opening of car or hoistway doors	Install door restrictor	No
1.15 Signs and operating device symbols	Install telephone	No
5.1 Pit access; lighting; stop switch; and condition	Water in pit ,install pit ladder and pit light	No
5.1 Pit access; lighting; stop switch; and condition	Bevel ledges in the hoistway	No

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0601	Device Type: Hydraulic Elevator	Date: 3/1/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Mike Robison	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	2 INSIDE OF CAR	OK	NG	N/A
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices	X			3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks			X
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways			X
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors			X	3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols			X	3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors			X	3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways	X		
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch			X
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition			X
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices			X
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy			X	5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000	X		
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00	X		
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04	X		
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07	X		
				6.8 A17.1-2010/B44-10	X		
				6.9 A17.1-2013/B44-13	X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Peltier Hall
207 Alumni Dr
Thibodaux, LA 70301

Location ID:
329003-17

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/1/2023

Inspection Start Time: 11:30:00 AM

Inspection End Time: 12:00:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: L0037

Device Type: Wheelchair Lift

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 9/22/2010

Device Manufacturer: Carrier

Cat 5 Required?

Capacity: 500

Speed: 10

Inspector Notes:

Testing Results:

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
10.2.2.a.5 Emergency signal	Repair alarm bell	Yes

Checklist and Report for Inspection of Lifts ASME A18.1-2020 Requirement: 10.2.2

ID No: L0037

Device Type: Wheelchair Lift

Date: 3/1/2023


Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: Mike Robison

Inspected By: Smith, Willie ||

Signature: 

Location Contact Signature:

Notes: OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

A	INSIDE PLATFORM INSPECTIONS	OK	NG	N/A	C	INSIDE RUNWAY INSPECTIONS	OK	NG	N/A
1	Stop switches	X			1	Platform, overhead, and deflector sheaves	X		
2	Operating control devices	X			2	Normal terminal stopping devices	X		
3	Floor and landing sill	X			3	Final terminal stopping devices	X		
4	Lighting	X			4	Broken rope, chain, or tape switch	X		
5	Emergency signal	X			5	Counterweight			X
6	Door or gate	X			6	Head room	X		
7	Enclosure	X			7	Slack-rope devices	X		
8	Floor	X			8	Traveling sheave	X		
9	Signs and operating device symbols	X			9	Platform safeties and guiding members			X
10	Rate load, platform floor area and data plate	X			10	Runway construction	X		
11	Ride	X			11	Pipes, wiring and ducts	X		
B MACHINE INSPECTIONS					D OUTSIDE RUNWAY INSPECTIONS				
1	Enclosure of machine space	X			12	Runway clearances	X		
2	Guarding of exposed auxiliary equipment	X			13	Traveling cables and junction boxes	X		
3	Overhead beam and fastenings	X			14	Door and gate equipment	X		
4	Drive-machine brake	X			15	Platform frame	X		
5	Traction drive machines	X			16	Guide rails fastening and equipment	X		
6	Gears and bearings	X			17	Governor rope			X
7	Winding drum machine			X	18	Governor releasing carrier			X
8	Belt- or chain-drive machine	X			19	Wire rope fastening and hitch plate			X
9	Traction sheaves	X			20	Suspension rope			X
10	Secondary and deflector sheaves	X			21	Compensation ropes and chains			X
11	Rope fastenings	X			1	Runway doors	X		
12	Slack-rope devices	X			2	Runway door locking devices	X		
13	Governor, overspeed switch and seal			X	3	Runway enclosure	X		
14	Platform safeties	X							
15	Hydraulic power unit	X							
16	Control valves	X							
17	Hydraulic cylinders	X							

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Peltier Hall
207 Alumni Dr
Thibodaux, LA 70301

Location ID:
329003-17

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/1/2023

Inspection Start Time: 11:00:00 AM

Inspection End Time: 11:30:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: L0036

Device Type: Wheelchair Lift

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 9/22/2007

Device Manufacturer: Porch Lift

Cat 5 Required?

Capacity: 750

Speed: 10

Inspector Notes:

Testing Results:

Violation Information:

Checklist and Report for Inspection of Lifts ASME A18.1-2020 Requirement: 10.2.2

ID No: L0036

Device Type: Wheelchair Lift

Date: 3/1/2023


Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: Mike Robison

Inspected By: Smith, Willie ||

Signature: 

Location Contact Signature:

Notes: OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

A INSIDE PLATFORM INSPECTIONS	OK	NG	N/A	C INSIDE RUNWAY INSPECTIONS	OK	NG	N/A
1 Stop switches	X			1 Platform, overhead, and deflector sheaves	X		
2 Operating control devices	X			2 Normal terminal stopping devices	X		
3 Floor and landing sill	X			3 Final terminal stopping devices	X		
4 Lighting	X			4 Broken rope, chain, or tape switch	X		
5 Emergency signal	X			5 Counterweight			X
6 Door or gate	X			6 Head room	X		
7 Enclosure	X			7 Slack-rope devices	X		
8 Floor	X			8 Traveling sheave			X
9 Signs and operating device symbols	X			9 Platform safeties and guiding members	X		
10 Rate load, platform floor area and data plate	X			10 Runway construction	X		
11 Ride	X			11 Pipes, wiring and ducts	X		
B MACHINE INSPECTIONS				12 Runway clearances	X		
1 Enclosure of machine space	X			13 Traveling cables and junction boxes	X		
2 Guarding of exposed auxiliary equipment	X			14 Door and gate equipment	X		
3 Overhead beam and fastenings	X			15 Platform frame	X		
4 Drive-machine brake	X			16 Guide rails fastening and equipment	X		
5 Traction drive machines			X	17 Governor rope			X
6 Gears and bearings			X	18 Governor releasing carrier			X
7 Winding drum machine			X	19 Wire rope fastening and hitch plate	X		
8 Belt- or chain-drive machine			X	20 Suspension rope			X
9 Traction sheaves			X	21 Compensation ropes and chains			X
10 Secondary and deflector sheaves	X			D OUTSIDE RUNWAY INSPECTIONS			
11 Rope fastenings	X			1 Runway doors	X		
12 Slack-rope devices			X	2 Runway door locking devices	X		
13 Governor, overspeed switch and seal			X	3 Runway enclosure	X		
14 Platform safeties	X						
15 Hydraulic power unit	X						
16 Control valves	X						
17 Hydraulic cylinders	X						

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Peltier Hall
207 Alumni Dr
Thibodaux, LA 70301

Location ID:
329003-17

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/1/2023

Inspection Start Time: 10:00:00 AM

Inspection End Time: 11:00:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0118

Device Type: Hydraulic Elevator

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 9/22/2001

Device Manufacturer: Tke

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 2500

Speed: 100

Inspector Notes:


Testing Results: Relief (psi): 510, Working (psi): 220,

Violation Information:

Previous Violations

<u>Previous Violation</u>	<u>Inspector Comments</u>	<u>Corrected?</u>
1.18 Restricted opening of car or hoistway doors	Repair door restrictor	Yes

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0118	Device Type: Hydraulic Elevator	Date: 3/1/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Mike Robison	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	2 INSIDE OF CAR	OK	NG	N/A
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices	X			3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks			X
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways			X
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors			X	3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation			X	3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch			X
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices	X		
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
				5.17 Plunger gripper			X
3 TOP OF CAR				6 FIREFIGHTERS' SERVICE (FEO)			
3.1 Top-of-car stop switch	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.2 Car top light and outlet	X			6.2 A17.1b-1989 through A17.1d-2000	X		
3.3 Top-of-car operating device	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.5 Normal terminal stopping devices	X			6.5 A 17.1-2000/644-00	X		
3.6 Final and emergency terminal stopping devices	X			6.6 A 17.1-2004/644-04	X		
3.7 Top-of-car operating device	X			6.7 A17.1-2007/B44-07	X		
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.8 A17.1-2010/B44-10	X		
				6.9 A17.1-2013/B44-13	X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Betsy Cheramie Ayo Hall
200 Ardoyne Dr
Thibodaux, LA 70301

Location ID:
329003-70

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/1/2023

Inspection Start Time: 2:00:00 PM

Inspection End Time: 3:00:00 PM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0596

Device Type: Hydraulic Elevator

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 3/15/1996

Device Manufacturer: Northern

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 4500


Speed: 100

Inspector Notes:

Testing Results: Relief (psi): 440, Working (psi): 220,

Violation Information:

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0596	Device Type: Hydraulic Elevator	Date: 3/1/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Mike Robison	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	OK NG N/A			
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices	X			3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks			X
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways			X
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors			X	3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Crosshead data plate and rope data tags	X		
1.17 Standby power operation			X	3.28 Counterweight and counterweight buffer			X
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators			X
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices			X
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch			X
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices	X		
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators			X	5.8 Car and counterweight safeties and guiding members	X		
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation			X	5.15 Overspeed valve	X		
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)	X		
				5.17 Plunger gripper	X		
3 TOP OF CAR				6 FIREFIGHTERS' SERVICE (FEO)			
3.1 Top-of-car stop switch	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.2 Car top light and outlet	X			6.2 A17.1b-1989 through A17.1d-2000	X		
3.3 Top-of-car operating device	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.5 Normal terminal stopping devices	X			6.5 A 17.1-2000/644-00	X		
3.6 Final and emergency terminal stopping devices	X			6.6 A 17.1-2004/644-04	X		
3.7 Top-of-car operating device	X			6.7 A17.1-2007/B44-07	X		
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.8 A17.1-2010/B44-10	X		
				6.9 A17.1-2013/B44-13	X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Betsy Cheramie Ayo Hall
200 Ardoyne Dr
Thibodaux, LA 70301

Location ID:
329003-70

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/1/2023

Inspection Start Time: 3:00:00 PM

Inspection End Time: 4:00:00 PM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0595

Device Type: Hydraulic Elevator

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 3/15/1996

Device Manufacturer: Northern

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 2500


Speed: 100

Inspector Notes:

Testing Results: Relief (psi): 440, Working (psi): 200,

Violation Information:

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0595	Device Type: Hydraulic Elevator	Date: 3/1/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Mike Robison	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	OK NG N/A			
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices	X			3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks	X		
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways	X		
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope	X		
1.13 Emergency exit	X			3.21 Governor releasing carrier	X		
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate	X		
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems	X		
1.16 Rated load, platform area, and data plate	X			3.27 Croshead data plate and rope data tags	X		
1.17 Standby power operation	X			3.28 Counterweight and counterweight buffer	X		
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties	X		
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)	X			3.31 Slack rope test - roped hydraulic elevators	X		
2 MACHINE ROOM				3.32 Speed Test	X		
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)	X		
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices	X		
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways	X		
2.13 Governor, overspeed switch, and seal	X			4.12 Standby power selection switch	X		
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices	X		
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators	X			5.8 Car and counterweight safeties and guiding members	X		
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)	X			5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve	X		
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)	X		
				5.17 Plunger gripper	X		
3 TOP OF CAR				6 FIREFIGHTERS' SERVICE (FEO)			
3.1 Top-of-car stop switch	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.2 Car top light and outlet	X			6.2 A17.1b-1989 through A17.1d-2000	X		
3.3 Top-of-car operating device	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.5 Normal terminal stopping devices	X			6.5 A 17.1-2000/644-00	X		
3.6 Final and emergency terminal stopping devices	X			6.6 A 17.1-2004/644-04	X		
3.7 Top-of-car operating device	X			6.7 A17.1-2007/B44-07	X		
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.8 A17.1-2010/B44-10	X		
				6.9 A17.1-2013/B44-13	X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Zeringue Residence Hall
130 Bowie Rd
Thibodaux, LA 70301

Location ID:
329003-90

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/2/2023

Inspection Start Time: 11:30:00 AM

Inspection End Time: 12:30:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0605

Device Type: Hydraulic Elevator

of Landings:

Due Month: March

Device Use:

Device Designation: EY5357

Code Edition:

Installation Date: 9/23/2008

Device Manufacturer: Tke

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 3500

Speed: 100

Inspector Notes:

Testing Results: Relief (psi): 300, Working (psi): 170,

Violation Information:

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Millet Hall
130 Bowie Rd
Thibodaux, LA 70301

Location ID:
329003-089

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/2/2023

Inspection Start Time: 10:30:00 AM

Inspection End Time: 11:30:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0117

Device Type: Hydraulic Elevator

of Landings:

Due Month: March

Device Use:

Device Designation: EV5366

Code Edition:

Installation Date: 9/23/2004

Device Manufacturer: Tke

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 3500


Speed: 100

Inspector Notes:

Testing Results: Relief (psi): 450, Working (psi): 180,

Violation Information:

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0117	Device Type: Hydraulic Elevator	Date: 3/2/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Mike Robison	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	2 INSIDE OF CAR	OK	NG	N/A
1.1 Door reopening device	X			3.9 Floor and emergency identification numbering	X		
1.2 Stop Switches	X			3.10 Hoistway Construction	X		
1.3 Operating control devices	X			3.11 Hoistway smoke control	X		
1.4 Sills and car floor	X			3.12 Pipes, wiring, and ducts	X		
1.5 Car lighting and receptacles	X			3.13 Windows, projections, recesses, and setbacks			X
1.6 Car emergency signal	X			3.14 Hoistway clearances	X		
1.7 Car door or gate	X			3.15 Multiple hoistways			X
1.8 Door closing force	X			3.16 Traveling cables and junction boxes	X		
1.9 Power closing of doors or gates	X			3.17 Door and gate equipment	X		
1.10 Power opening of doors or gates	X			3.18 Car frame and stiles	X		
1.11 Car vision panels and glass car doors	X			3.19 Guide rails, fastenings, and equipment	X		
1.12 Car enclosure	X			3.20 Governor rope			X
1.13 Emergency exit	X			3.21 Governor releasing carrier			X
1.14 Ventilation	X			3.22 Wire rope fastening and hitch plate			X
1.15 Signs and operating device symbols	X			3.23 Suspension compensation and governor systems			X
1.16 Rated load, platform area, and data plate	X			3.27 Croshead data plate and rope data tags	X		
1.17 Standby power operation			X	3.28 Counterweight and counterweight buffer	X		
1.18 Restricted opening of car or hoistway doors	X			3.29 Counterweight safeties			X
1.19 Car ride	X			3.30 Speed Test	X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	3.31 Slack rope test - roped hydraulic elevators	X		
2 MACHINE ROOM				3.32 Speed Test			X
2.1 Access to machinery space	X			3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
2.2 Headroom	X			4 OUTSIDE HOISTWAY			
2.3 Lighting and receptacles	X			4.1 Car platform guard	X		
2.4 Machinery space	X			4.2 Hoistway doors	X		
2.5 Housekeeping	X			4.3 Vision panels	X		
2.6 Ventilation	X			4.4 Hoistway door-locking devices	X		
2.7 Fire extinguisher	X			4.5 Access to hoistway	X		
2.8 Pipes, wiring, and ducts	X			4.6 Power closing of hoistway doors	X		
2.9 Guarding of exposed auxiliary equipment	X			4.7 Sequence operation	X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			4.8 Hoistway enclosure	X		
2.11 Disconnecting means and control	X			4.9 Elevator parking devices			X
2.12 Controller wiring, fuses, grounding, etc.	X			4.10 Emergency doors in blind hoistways			X
2.13 Governor, overspeed switch, and seal			X	4.12 Standby power selection switch			X
2.14 Code data plate	X			5 PIT			
2.30 Hydraulic power unit	X			5.1 Pit access, lighting, stop switch & condition	X		
2.31 Relief valves	X			5.2 Bottom clearance, runby & minimum refuge space	X		
2.32 Control valve	X			5.4 Normal terminal stopping devices	X		
2.33 Tanks	X			5.5 Traveling cables	X		
2.36 Hydraulic cylinders	X			5.6 Governor-rope tension devices	X		
2.37 Pressure switch	X			5.7 Car frame and platform	X		
2.38 Roped water hydraulic elevators	X			5.8 Car and counterweight safeties and guiding members			X
2.39 Low oil protection	X			5.11 Buffers and emergency terminal speed-limiting devices	X		
2.40 Maintenance records	X			5.12 Car buffers	X		
2.41 Hydraulic control	X			5.13 Guiding members [rails, rollers, slides]	X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	5.14 Guiding members [rails, rollers, slides]	X		
2.44 Auxillary power lowering operation	X			5.15 Overspeed valve			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X
3 TOP OF CAR				5.17 Plunger gripper			X
3.1 Top-of-car stop switch	X			6 FIREFIGHTERS' SERVICE (FEO)			
3.2 Car top light and outlet	X			6.1 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.3 Top-of-car operating device	X			6.2 A17.1b-1989 through A17.1d-2000	X		
3.4 Top-of-car clearance, refuge space, and standard railing	X			6.3 A17.1-1984 through A17.1a-1988 and A17.3	X		
3.5 Normal terminal stopping devices	X			6.4 A17.1b-1989 through A17.1d-2000	X		
3.6 Final and emergency terminal stopping devices	X			6.5 A 17.1-2000/644-00	X		
3.7 Top-of-car operating device	X			6.6 A 17.1-2004/644-04	X		
3.8 Top-of-car clearance, refuge space, and standard railing	X			6.7 A17.1-2007/B44-07	X		
				6.8 A17.1-2010/B44-10	X		
				6.9 A17.1-2013/B44-13	X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Zeringue Residence Hall
130 Bowie Rd
Thibodaux, LA 70301

Location ID:
329003-90

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/2/2023

Inspection Start Time: 11:30:00 AM

Inspection End Time: 12:30:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0605

Device Type: Hydraulic Elevator

of Landings:

Due Month: March

Device Use:

Device Designation: EY5357

Code Edition:

Installation Date: 9/23/2008

Device Manufacturer: Tke

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 3500


Speed: 100

Inspector Notes:

Testing Results: Relief (psi): 300, Working (psi): 170,

Violation Information:

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0605	Device Type: Hydraulic Elevator	Date: 3/2/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Mike Robison	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	OK NG N/A
1.1 Door reopening device	X			X
1.2 Stop Switches	X			X
1.3 Operating control devices	X			X
1.4 Sills and car floor	X			X
1.5 Car lighting and receptacles	X			X
1.6 Car emergency signal	X			X
1.7 Car door or gate	X			X
1.8 Door closing force	X			X
1.9 Power closing of doors or gates	X			X
1.10 Power opening of doors or gates	X			X
1.11 Car vision panels and glass car doors			X	
1.12 Car enclosure	X			X
1.13 Emergency exit	X			X
1.14 Ventilation	X			X
1.15 Signs and operating device symbols	X			X
1.16 Rated load, platform area, and data plate	X			X
1.17 Standby power operation			X	
1.18 Restricted opening of car or hoistway doors	X			X
1.19 Car ride	X			X
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	
2 MACHINE ROOM	OK	NG	N/A	OK NG N/A
2.1 Access to machinery space	X			X
2.2 Headroom	X			X
2.3 Lighting and receptacles	X			X
2.4 Machinery space	X			X
2.5 Housekeeping	X			X
2.6 Ventilation	X			X
2.7 Fire extinguisher	X			X
2.8 Pipes, wiring, and ducts	X			X
2.9 Guarding of exposed auxiliary equipment	X			X
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			X
2.11 Disconnecting means and control	X			X
2.12 Controller wiring, fuses, grounding, etc.	X			X
2.13 Governor, overspeed switch, and seal			X	
2.14 Code data plate	X			X
2.30 Hydraulic power unit	X			X
2.31 Relief valves	X			X
2.32 Control valve	X			X
2.33 Tanks	X			X
2.36 Hydraulic cylinders	X			X
2.37 Pressure switch	X			X
2.38 Roped water hydraulic elevators			X	
2.39 Low oil protection	X			X
2.40 Maintenance records	X			X
2.41 Hydraulic control	X			X
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	
2.44 Auxillary power lowering operation	X			X
2.45 Inspection operation with open door circuits and inspection hierarchy	X			X
3 TOP OF CAR	OK	NG	N/A	OK NG N/A
3.1 Top-of-car stop switch	X			X
3.2 Car top light and outlet	X			X
3.3 Top-of-car operating device	X			X
3.4 Top-of-car clearance, refuge space, and standard railing	X			X
3.5 Normal terminal stopping devices	X			X
3.6 Final and emergency terminal stopping devices	X			X
3.7 Top-of-car operating device	X			X
3.8 Top-of-car clearance, refuge space, and standard railing	X			X
4 OUTSIDE HOISTWAY	OK	NG	N/A	OK NG N/A
4.1 Car platform guard	X			X
4.2 Hoistway doors	X			X
4.3 Vision panels			X	
4.4 Hoistway door-locking devices	X			X
4.5 Access to hoistway	X			X
4.6 Power closing of hoistway doors	X			X
4.7 Sequence operation	X			X
4.8 Hoistway enclosure	X			X
4.9 Elevator parking devices	X			X
4.10 Emergency doors in blind hoistways			X	
4.12 Standby power selection switch			X	
5 PIT	OK	NG	N/A	OK NG N/A
5.1 Pit access, lighting, stop switch & condition	X			X
5.2 Bottom clearance, runby & minimum refuge space	X			X
5.4 Normal terminal stopping devices	X			X
5.5 Traveling cables	X			X
5.6 Governor-rope tension devices			X	
5.7 Car frame and platform	X			X
5.8 Car and counterweight safeties and guiding members	X			X
5.11 Buffers and emergency terminal speed-limiting devices	X			X
5.12 Car buffers	X			X
5.13 Guiding members [rails, rollers, slides]	X			X
5.14 Guiding members [rails, rollers, slides]	X			X
5.15 Overspeed valve			X	
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	
5.17 Plunger gripper			X	
6 FIREFIGHTERS' SERVICE (FEO)	OK	NG	N/A	OK NG N/A
6.1 A17.1-1984 through A17.1a-1988 and A17.3	X			X
6.2 A17.1b-1989 through A17.1d-2000	X			X
6.3 A17.1-1984 through A17.1a-1988 and A17.3	X			X
6.4 A17.1b-1989 through A17.1d-2000	X			X
6.5 A 17.1-2000/644-00	X			X
6.6 A 17.1-2004/644-04	X			X
6.7 A17.1-2007/B44-07	X			X
6.8 A17.1-2010/B44-10	X			X
6.9 A17.1-2013/B44-13	X			X

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Talbot Hall
106 Ellendale Drive (Entrance L)
Thibodaux, LA 70310

Location ID:
329003-022

Location Contact Information:

Name: Chad Legendre
Title:
Phone: +19854484785
Email: chad.legendre@nicholls.edu

Inspection Information:

Inspection Date: 3/3/2023

Inspector: Smith, Willie ||

Re-Inspection Required: No

Device ID: T0281

Due Month: March

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 7:00:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use:

Installation Date: 9/22/2007

Capacity: 2500

Inspection End Time: 8:30:00 AM

Inspection Result: Passed - No Violations

Re-Inspection Maint Co Required: No

of Landings:

Device Designation:

Device Manufacturer: Tke

Speed: 150

Violation Information:

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
College Of Science And Technology
Building
201 Alumni Dr
Thibodaux, LA 70301

Location ID:
329003-9

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/1/2023

Inspection Start Time: 9:00:00 AM

Inspection End Time: 10:00:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: H0110

Device Type: Hydraulic Elevator

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 3/15/1987

Device Manufacturer: Tke

Overspeed Valve?

Plunger Gripper?

Cat 5 Required?

Capacity: 2100


Speed: 100

Inspector Notes:

Testing Results: Relief (psi): 440, Working (psi): 160,

Violation Information:

Checklist and Report for Inspection of Hydraulic Elevators ASME A17.2-2020

ID No: H0110	Device Type: Hydraulic Elevator	Date: 3/1/2023	Inspection Type: Category 1 Test
Firm #: 33	Code Edition:	Location Contact Name: Mike Robison	
Inspected By: Smith, Willie	Signature: 	Location Contact Signature:	

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1 INSIDE OF CAR	OK	NG	N/A	OK	NG	N/A
1.1 Door reopening device	X			X		
1.2 Stop Switches	X			X		
1.3 Operating control devices	X			X		
1.4 Sills and car floor	X			X		
1.5 Car lighting and receptacles	X			X		
1.6 Car emergency signal	X			X		
1.7 Car door or gate	X			X		
1.8 Door closing force	X			X		
1.9 Power closing of doors or gates	X			X		
1.10 Power opening of doors or gates	X			X		
1.11 Car vision panels and glass car doors			X	X		
1.12 Car enclosure	X			X		
1.13 Emergency exit	X			X		
1.14 Ventilation	X			X		
1.15 Signs and operating device symbols	X			X		
1.16 Rated load, platform area, and data plate	X			X		
1.17 Standby power operation			X	X		
1.18 Restricted opening of car or hoistway doors	X			X		
1.19 Car ride	X			X		
1.20 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	X		
2 MACHINE ROOM						
2.1 Access to machinery space	X			X		
2.2 Headroom	X			X		
2.3 Lighting and receptacles	X			X		
2.4 Machinery space	X			X		
2.5 Housekeeping	X			X		
2.6 Ventilation	X			X		
2.7 Fire extinguisher	X			X		
2.8 Pipes, wiring, and ducts	X			X		
2.9 Guarding of exposed auxiliary equipment	X			X		
2.10 Numbering of elevators, machines, controllers & disconnect switches	X			X		
2.11 Disconnecting means and control	X			X		
2.12 Controller wiring, fuses, grounding, etc.	X			X		
2.13 Governor, overspeed switch, and seal			X	X		
2.14 Code data plate	X			X		
2.30 Hydraulic power unit	X			X		
2.31 Relief valves	X			X		
2.32 Control valve	X			X		
2.33 Tanks	X			X		
2.36 Hydraulic cylinders	X			X		
2.37 Pressure switch	X			X		
2.38 Roped water hydraulic elevators			X	X		
2.39 Low oil protection	X			X		
2.40 Maintenance records	X			X		
2.41 Hydraulic control	X			X		
2.42 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	X		
2.44 Auxillary power lowering operation	X			X		
2.45 Inspection operation with open door circuits and inspection hierarchy	X			X		
3 TOP OF CAR						
3.1 Top-of-car stop switch	X			X		
3.2 Car top light and outlet	X			X		
3.3 Top-of-car operating device	X			X		
3.4 Top-of-car clearance, refuge space, and standard railing	X			X		
3.5 Normal terminal stopping devices	X			X		
3.6 Final and emergency terminal stopping devices	X			X		
3.7 Top-of-car operating device	X			X		
3.8 Top-of-car clearance, refuge space, and standard railing	X			X		
3.9 Floor and emergency identification numbering	X			X		
3.10 Hoistway Construction	X			X		
3.11 Hoistway smoke control	X			X		
3.12 Pipes, wiring, and ducts	X			X		
3.13 Windows, projections, recesses, and setbacks			X	X		
3.14 Hoistway clearances	X			X		
3.15 Multiple hoistways	X			X		
3.16 Traveling cables and junction boxes	X			X		
3.17 Door and gate equipment	X			X		
3.18 Car frame and stiles	X			X		
3.19 Guide rails, fastenings, and equipment	X			X		
3.20 Governor rope	X			X		
3.21 Governor releasing carrier	X			X		
3.22 Wire rope fastening and hitch plate			X	X		
3.23 Suspension compensation and governor systems			X	X		
3.27 Crosshead data plate and rope data tags	X			X		
3.28 Counterweight and counterweight buffer			X	X		
3.29 Counterweight safeties			X	X		
3.30 Speed Test	X			X		
3.31 Slack rope test - roped hydraulic elevators			X	X		
3.32 Speed Test			X	X		
3.34 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	X		
4 OUTSIDE HOISTWAY						
4.1 Car platform guard	X			X		
4.2 Hoistway doors	X			X		
4.3 Vision panels			X	X		
4.4 Hoistway door-locking devices	X			X		
4.5 Access to hoistway	X			X		
4.6 Power closing of hoistway doors	X			X		
4.7 Sequence operation	X			X		
4.8 Hoistway enclosure	X			X		
4.9 Elevator parking devices	X			X		
4.10 Emergency doors in blind hoistways			X	X		
4.12 Standby power selection switch			X	X		
5 PIT						
5.1 Pit access, lighting, stop switch & condition	X			X		
5.2 Bottom clearance, runby & minimum refuge space	X			X		
5.4 Normal terminal stopping devices	X			X		
5.5 Traveling cables	X			X		
5.6 Governor-rope tension devices	X			X		
5.7 Car frame and platform	X			X		
5.8 Car and counterweight safeties and guiding members	X			X		
5.11 Buffers and emergency terminal speed-limiting devices	X			X		
5.12 Car buffers	X			X		
5.13 Guiding members [rails, rollers, slides]	X			X		
5.14 Guiding members [rails, rollers, slides]	X			X		
5.15 Overspeed valve			X	X		
5.16 Earthquake inspection and tests (seismic risk zone 2 or greater)			X	X		
5.17 Plunger gripper			X	X		
6 FIREFIGHTERS' SERVICE (FEO)						
6.1 A17.1-1984 through A17.1a-1988 and A17.3	X			X		
6.2 A17.1b-1989 through A17.1d-2000	X			X		
6.3 A17.1-1984 through A17.1a-1988 and A17.3	X			X		
6.4 A17.1b-1989 through A17.1d-2000	X			X		
6.5 A 17.1-2000/644-00	X			X		
6.6 A 17.1-2004/644-04	X			X		
6.7 A17.1-2007/B44-07	X			X		
6.8 A17.1-2010/B44-10	X			X		
6.9 A17.1-2013/B44-13	X			X		

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Guidry Football Stadium
331 Alumni Dr
Thibodaux, LA 70301

Location ID:
329003-27

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/3/2023

Inspector: Smith, Willie ||

Re-Inspection Required: No

Device ID: T0277

Due Month: March

Code Edition:

Cat 5 Required?

Inspector Notes:

Testing Results:

Inspection Start Time: 11:30:00 AM

Inspection Type: Category 1 Test

Generator Test Performed: No

Device Type: Traction Elevator

Device Use:

Installation Date: 9/23/2011

Capacity: 3500

Inspection End Time: 1:00:00 PM

Inspection Result: Passed - Violations

Re-Inspection Maint Co Required: No

of Landings:

Device Designation:

Device Manufacturer: EC

Speed: 350

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020


Address: Guidry Football Stadium, 331 Alumni Dr, Thibodaux, LA 70301

ID No: T0277 **Device Type:** Traction Elevator

Date: 3/3/2023 **Inspection Type:** Category 1 Test

Firm #: 33 **Code Edition:**

Location Contact Name: Mike Robison

Inspected By: Smith, Willie || **Signature:** 

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1	INSIDE OF CAR			OK	NG	N/A	
1.1	Door reopening device	X					
1.2	Stop Switches	X					
1.3	Operating control devices	X					
1.4	Sills and car floor	X					
1.5	Car lighting and receptacles	X					
1.6	Car emergency signal	X					
1.7	Car door or gate	X					
1.8	Door closing force	X					
1.9	Power closing of doors or gates	X					
1.10	Power opening of doors or gates	X					
1.11	Car vision panels and glass car doors	X					
1.12	Car enclosure	X					
1.13	Emergency exit	X					
1.14	Ventilation	X					
1.15	Signs and operating device symbols	X					
1.16	Rated load, platform area, and data plate	X					
1.17	Standby power operation	X					
1.18	Restricted opening of car or hoistway doors	X					
1.19	Car ride	X					
1.20	Earthquake inspection and tests (seismic risk zone 2 or greater)	X					
2	MACHINE ROOM						
2.1	Access to machinery space	X					
2.2	Headroom	X					
2.3	Lighting and receptacles	X					
2.4	Machinery space	X					
2.5	Housekeeping	X					
2.6	Ventilation	X					
2.7	Fire extinguisher	X					
2.8	Pipes, wiring, and ducts	X					
2.9	Guarding of exposed auxiliary equipment	X					
2.10	Numbering of elevators, machines, controllers & disconnect switches	X					
2.11	Disconnecting means and control	X					
2.12	Controller wiring, fuses, grounding, etc.	X					
2.13	Governor, overspeed switch, and seal	X					
2.14	Code data plate	X					
2.15	Static control	X					
2.16	Overhead beam and fastenings	X					
2.17	Drive machine brake	X					
2.18	Traction-drive machines	X					
2.19	Gears, bearings, and flexible couplings	X					
2.20	Winding drum machine & slack rope device, stop-motion switch, & rope fastening	X					
2.21	Belt- or chain-drive machine	X					
2.22	Motor generator	X					
2.23	Absorption of regenerated power	X					
2.24	AC drives from a DC source	X					
2.25	Traction sheaves	X					
2.26	Secondary and deflector sheaves	X					
2.27	Rope fastenings	X					
2.28	Terminal stopping devices	X					
2.29	Car and counterweight safeties	X					
2.40	Maintenance records	X					
2.42	Earthquake inspection and tests (seismic risk zone 2 or greater)	X					
3	TOP OF CAR						
3.1	Top-of-car stop switch	X					
3.2	Car top light and outlet	X					
3.3	Top-of-car operating device	X					
3.4	Top-of-car clearance, refuge space, and standard railing	X					
3.5	Normal terminal stopping devices	X					
3.6	Final and emergency terminal stopping devices	X					
4	OUTSIDE HOISTWAY						
4.1	Car platform guard	X					
4.2	Hoistway doors	X					
4.3	Vision panels	X					
4.4	Hoistway door-locking devices	X					
4.5	Access to hoistway	X					
4.6	Power closing of hoistway doors	X					
4.7	Sequence operation	X					
4.8	Hoistway enclosure	X					
4.9	Elevator parking devices	X					
4.10	Emergency doors in blind hoistways	X					
4.12	Standby power selection switch	X					
5	PIT						
5.1	Pit access, lighting, stop switch & condition	X					
5.2	Bottom clearance, runby & minimum refuge space	X					
5.3	Final and emergency terminal stopping devices	X					
5.4	Normal terminal stopping devices	X					
5.5	Traveling cables	X					
5.6	Governor-rope tension devices	X					
5.7	Car frame and platform	X					
5.8	Car and counterweight safeties and guiding members	X					
5.9	Buffers and emergency terminal speed-limiting devices	X					
5.10	Compensating chains, ropes & sheaves	X					
5.12	Car buffers	X					
5.13	Guiding members [rails, rollers, slides]	X					
5.16	Earthquake inspection and tests (seismic risk zone 2 or greater)	X					
6	FIREFIGHTERS' SERVICE (FEO)						
6.1	A17.1b-1973 through A17.1b-1980	X					
6.2	17.1-1981 through A17.1b-1983	X					
6.3	A17.1-1984 through A17.1a-1988 and A17.3	X					
6.4	A17.1b-1989 through A17.1d-2000	X					
6.5	A 17.1-2000/644-00	X					
6.6	A 17.1-2004/644-04	X					
6.7	A17.1-2007/B44-07	X					
6.8	A17.1-2010/B44-10	X					
6.9	A17.1-2013/B44-13	X					

Agency Information:

Agency Address:

Maintenance Company Information:

Maintenance Company:
EMR Services

Building Information:

Location Address:
Harold J. Callais Memorial Recreation
Center
147 Bowie Road
Thibodaux, LA 70301

Location ID:
329003-95

Location Contact Information:
Name: Mike Robison
Title:
Phone: +19854484773
Email: mike.robison@nicholls.edu

Inspection Information:

Inspection Date: 3/3/2023

Inspection Start Time: 8:30:00 AM

Inspection End Time: 10:00:00 AM

Inspector: Smith, Willie ||

Inspection Type: Category 1 Test

Inspection Result: Passed - No Violations

Re-Inspection Required: No

Generator Test Performed: No

Re-Inspection Maint Co Required: No

Device ID: T0278

Device Type: Traction Elevator

of Landings:

Due Month: March

Device Use:

Device Designation:

Code Edition:

Installation Date: 9/23/2012

Device Manufacturer: Kone

Cat 5 Required?

Capacity: 2500

Speed: 150

Inspector Notes:

Testing Results:

Violation Information:

Checklist and Report for Inspection of Electric Elevators ASME A17.2-2020

Address:

ID No: T0278

Device Type: Traction Elevator

Date: 3/3/2023


Inspection Type: Category 1 Test

Firm #: 33

Code Edition:

Location Contact Name: Mike Robison

Inspected By: Smith, Willie ||

Signature: 

Location Contact Signature:

Notes: See ASME A17.2 for detailed Code requirements. Numbering is tied to the numbering of A 17.2 Items. OK= meets requirements; NG= doesn't meet requirements; N/A = not applicable.

1	INSIDE OF CAR	OK	NG	N/A		OK	NG	N/A
1.1	Door reopening device	X				X		
1.2	Stop Switches	X				X		
1.3	Operating control devices	X				X		
1.4	Sills and car floor	X				X		
1.5	Car lighting and receptacles	X				X		
1.6	Car emergency signal	X				X		
1.7	Car door or gate	X				X		
1.8	Door closing force	X				X		
1.9	Power closing of doors or gates	X				X		
1.10	Power opening of doors or gates	X				X		
1.11	Car vision panels and glass car doors	X				X		
1.12	Car enclosure	X				X		
1.13	Emergency exit	X				X		
1.14	Ventilation	X				X		
1.15	Signs and operating device symbols	X				X		
1.16	Rated load, platform area, and data plate	X				X		
1.17	Standby power operation	X				X		
1.18	Restricted opening of car or hoistway doors	X				X		
1.19	Car ride	X				X		
1.20	Earthquake inspection and tests (seismic risk zone 2 or greater)	X				X		
2	MACHINE ROOM							
2.1	Access to machinery space	X				X		
2.2	Headroom	X				X		
2.3	Lighting and receptacles	X				X		
2.4	Machinery space	X				X		
2.5	Housekeeping	X				X		
2.6	Ventilation	X				X		
2.7	Fire extinguisher	X				X		
2.8	Pipes, wiring, and ducts	X				X		
2.9	Guarding of exposed auxiliary equipment	X				X		
2.10	Numbering of elevators, machines, controllers & disconnect switches	X				X		
2.11	Disconnecting means and control	X				X		
2.12	Controller wiring, fuses, grounding, etc.	X				X		
2.13	Governor, overspeed switch, and seal	X				X		
2.14	Code data plate	X				X		
2.15	Static control	X				X		
2.16	Overhead beam and fastenings	X				X		
2.17	Drive machine brake	X				X		
2.18	Traction-drive machines	X				X		
2.19	Gears, bearings, and flexible couplings	X				X		
2.20	Winding drum machine & slack rope device, stop-motion switch, & rope fastening	X				X		
2.21	Belt- or chain-drive machine	X				X		
2.22	Motor generator	X				X		
2.23	Absorption of regenerated power	X				X		
2.24	AC drives from a DC source	X				X		
2.25	Traction sheaves	X				X		
2.26	Secondary and deflector sheaves	X				X		
2.27	Rope fastenings	X				X		
2.28	Terminal stopping devices	X				X		
2.29	Car and counterweight safeties	X				X		
2.40	Maintenance records	X				X		
2.42	Earthquake inspection and tests (seismic risk zone 2 or greater)	X				X		
3	TOP OF CAR							
3.1	Top-of-car stop switch	X				X		
3.2	Car top light and outlet	X				X		
3.3	Top-of-car operating device	X				X		
3.4	Top-of-car clearance, refuge space, and standard railing	X				X		
3.5	Normal terminal stopping devices	X				X		
3.6	Final and emergency terminal stopping devices	X				X		
4	OUTSIDE HOISTWAY							
4.1	Car platform guard	X				X		
4.2	Hoistway doors	X				X		
4.3	Vision panels	X				X		
4.4	Hoistway door-locking devices	X				X		
4.5	Access to hoistway	X				X		
4.6	Power closing of hoistway doors	X				X		
4.7	Sequence operation	X				X		
4.8	Hoistway enclosure	X				X		
4.9	Elevator parking devices	X				X		
4.10	Emergency doors in blind hoistways	X				X		
4.12	Standby power selection switch	X				X		
5	PIT							
5.1	Pit access, lighting, stop switch & condition	X				X		
5.2	Bottom clearance, runby & minimum refuge space	X				X		
5.3	Final and emergency terminal stopping devices	X				X		
5.4	Normal terminal stopping devices	X				X		
5.5	Traveling cables	X				X		
5.6	Governor-rope tension devices	X				X		
5.7	Car frame and platform	X				X		
5.8	Car and counterweight safeties and guiding members	X				X		
5.9	Buffers and emergency terminal speed-limiting devices	X				X		
5.10	Compensating chains, ropes & sheaves	X				X		
5.12	Car buffers	X				X		
5.13	Guiding members [rails, rollers, slides]	X				X		
5.16	Earthquake inspection and tests (seismic risk zone 2 or greater)	X				X		
6	FIREFIGHTERS' SERVICE (FEO)							
6.1	A17.1b-1973 through A17.1b-1980	X				X		
6.2	17.1-1981 through A17.1b-1983	X				X		
6.3	A17.1-1984 through A17.1a-1988 and A17.3	X				X		
6.4	A17.1b-1989 through A17.1d-2000	X				X		
6.5	A 17.1-2000/644-00	X				X		
6.6	A 17.1-2004/644-04	X				X		
6.7	A17.1-2007/B44-07	X				X		
6.8	A17.1-2010/B44-10	X				X		
6.9	A17.1-2013/B44-13	X				X		