



Nicholls State University

Purchasing Office

P. O. Box 2052 – Thibodaux, LA 70310
985.448.4038 – Fax: 985.448.4921

**ADDENDUM NO 3
FOR
NICHOLLS STATE UNIVERSITY
THIBODAUX, LOUISIANA
04/02/2025**

PAGE 1 OF 1

**Bid SB01898 – Stopher Gym Air Handler Replacement
Nicholls State University 220 NSU-Colonel Drive, Thibodaux, LA 70301
Project No. 01-107-24-05 Schedule No 213, F.01004609**

Bid Responses are Due at 3:00 PM on 04/16/2025

This addendum is hereby made a part of the Bidding Documents to the extent as though it was originally included therein.

This addendum, Must be acknowledged on the Public Works Bid Form

Purpose of Addendum:

1. Answer Question Received

REQUEST FOR INFORMATION RESPONSES:

Mechanical: RFI #1 Responses

1. I see on Sheet ME2 under Steps Prior to Startup; it talks about chemical treatment, but doesn't have anything in the specs. Please advise if water treatment is required.
 - a. The shut-off valves and the balancing valve shown to be replaced at the connections between the new hot water piping and the existing shall remain and be reused. All other valving, unions, thermometers, and connections shall be replaced as shown. The contractor shall only need to drain the heating hot water between the existing shut-off (isolation valves); therefore, chemical treatment shall not be required. Remove the replacement of the shut-off valves and balancing valve connecting the new to existing hot water piping, the draining of the heating hot water system and the corresponding chemical treatment from the scope of work in the contract drawings and specifications.

This addendum will be uploaded to the Nicholls State Purchasing Department
Web Page <https://www.nicholls.edu/purchasing/> Posted under Bid Documents

Terry G. Dupre
Director of Purchasing, Property Control
and Support Services Administration